

Certificate

Registration No.: PV 60026760

Page 1

Report No.: 21210119-2

License Holder:

Nantong Qiangsheng Photovoltaic Technology Co., Ltd.

North Side, Jia Ling Jiang Road
Rudong Economic Techn. Development Zone
Rudong County, Nantong, Jiangsu 226400
China

Product:

PV Modules

Type: QS-50DGF
QS-55DGF
QS-60DGF

Manufacturing Plant:

Nantong Qiangsheng Photovoltaic Technology Co., Ltd.

North Side, Jia Ling Jiang Road
Rudong Economic Techn. Development Zone
Rudong County, Nantong, Jiangsu 226400
China

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61646
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 21210120.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 19 May 2014.



Cologne, 7 September 2009

Dipl.-Ing. M. Adrian